

SAFETY AND BUILDINGS DIVISION
Plumbing Product Review
P.O. Box 2658
Madison, Wisconsin 53701-2658

TTY: Contact Through Relay

Scott Walker, Governor Dave Ross, Secretary

September 26, 2013 (Revised November 13, 2013)

INFILTRATOR SYSTEMS INC.
GOVERNMENT AFFAIRS DEPARTMENT
4 BUSINESS PARK RD
PO BOX 768
OLD SAYBROOK CT 06475

Re: Description: LEACHING CHAMBER

Manufacturer: INFILTRATOR SYSTEMS INC.

Product Name: QUICK 4 STANDARD Model Number(s): QUICK 4 STANDARD

(EISA for chambers with or without fabric = 19.1 sq. ft./chamber, EISA for end caps = 5.8 6.0 sq. ft./pair of end caps, Laying length of chamber = 4.0 ft., Laying length of end caps = 1.0 ft., Width = 34 inches, Height = 12 inches, Max. depth of bury = 8 ft., FOR BED INSTALLATIONS, MAx. DEPTH OF BURY IS REDUCED TO 48 IN.; Open Bottom area =

9.1 sq.ft./chamber, 3.5 sq.ft./pair of end caps)

Product File No: 20130190

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an alternate approval to s. SPS 383.44 (5)(a) & 384.5 based on the Wisconsin Statutes and the Wisconsin Administrative Code. **This alternate approval is valid until the end of September 2018**.

This approval supersedes the approval issued on 1/24/2008 under product file number 20070550.

This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number 20070550.

This alternate approval is contingent upon compliance with the following stipulation(s):

- This product must be installed in accordance with the manufacturer's printed instructions, product approval, and plan approval. If there is a conflict between the manufacturer's instructions and the product approval and/or plan approval, the product approval and/or plan approval will take precedence.
- When this product is installed in a dispersal cell that is sized based on the EISA rating stated in the regarding block of the product approval letter, this product must receive wastewater having a BOD5 value between 30 and 220 mg/L and a TSS value between 30 and 150 mg/L.
- When this product is installed in a distribution cell that is sized based on the EISA rating stated in the regarding block of the product approval letter, this product must be installed in individual excavations that create a row of chambers that are horizontally separated from other rows in other excavations by at least 3 feet. The 3-foot measurement is measured between the closest outside edges of the leaching chambers.
- When this product is installed in a distribution cell that is sized based on the EISA rating stated in the regarding block of the product approval letter, the distribution cell design must allow at least six inches of ponding in the chambers without backflow of wastewater into the drainpipe that discharges into the chambers.

SBD-10564-E (N.10/97) File Ref: 13019002.DOC

INFILTRATOR SYSTEMS INC

Page 2

September 26, 2013 Product File No: 20130190

- When this product is installed in a distribution cell that is sized based on the EISA rating stated in the regarding block of the product approval letter, this product must be installed in a distribution system, which has the top of the distribution cell at or below original grade.
- When this product is installed next to each other in a distribution cell that is NOT sized based on the EISA rating stated in the regarding block of the product approval letter, the effluent distribution area is equal to the length times the width of the chambered area. The use of geotextile fabric in this type of installation is optional.
- When this product is installed with geotextile fabric on the sides of this product in a distribution cell that is sized based on the EISA rating stated in the regarding block of the product approval letter, the geotextile fabric must meet all of the following specifications:
 - . Geotextile shall be non-woven
 - . Weight shall be 0.35 oz/sq yd to 1.5 oz/sq yd
 - . Apparent opening size (AOS) shall be 20-30 U.S. Sieve (ASTM D-4751).

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Glen A. Jones, M.S. **POWTS Product Reviewer** phone: (608) 267-5265 fax: (608) 267-9723

email: glen.jones@wi.gov